

DELHI TEST HOUSE

A-62/3, G.T. Karnal Road, Industrial Area, Opp. Hans Cinema, Azadpur, Delhi-110 033 (INDIA)
Phone : +91-11-47075555 (30 Lines) Fax : +91-11-47075550
e-mail : info@delhitesthouse.com



Issued to:
The Principal
Sachdeva Public School
Sector-13, Rohini,
Delhi - 110 085.



TC-6471

Report No. : 20336230322GEN2340
Date : 06-04-2023
Date of Receipt : 22-03-2023
Party Ref No : SPS(R)/ADMN/2023/1348 & DT:-
22.03.2023

Sample Description:-DRINKING WATER

TEST REPORT

Sl.no	Tests	Test Values	Test Method	Requirement IS:10500-2012,AMD- NO.1,2,3&4
1.CHEMICAL TESTING. (WATER)				
1	COLOUR, HAZEN UNITS	: <2	IS:3025(P-4):1983	5 Max. Acceptable Limit. 15 Max. Rejection Limit
2	ODOUR	: Agreeable	IS:3025(P-5):2018	Agreeable
3	TASTE	: Agreeable	IS:3025(P-7):2017	Agreeable
4	TURBIDITY, NTU	: <1	IS:3025(P-10):1984	1 Max Acceptable Limit. 5 Max Rejection Limit.
5	pH	: 6.67	IS:3025(P-11)-2022	6.5-8.5 No Relaxation Rejection Limit
6	TOTAL HARDNESS as CaCO ₃ , mg/l	: <1	IS:3025(P-21):2009	200 Max Acceptable Limit 600 Max Rejection Limit
7	IRON as Fe, mg/l	: BLQ(0.01)	IS:3025(P-53):2003	1.0 Max. Acceptable Limit No Relaxation Rejection Limit
8	CHLORIDE as Cl, mg/l	: 24.5	IS:3025(P-32):1988	250 Max Acceptable Limit 1000 Max Rejection Limit
9	TOTAL DISSOLVED SOLIDS, mg/l	: 82.0	IS:3025(P-16):1984	500 Max. Acceptable Limit 2000 Max Rejection Limit
10	FLUORIDE as F, mg/l	: <0.2	IS:3025(P-60):2008	1.0 Max. Acceptable Limit 1.5 Max. Rejection Limit
2.BIOLOGICAL TESTING. (WATER)				
1	Coliform Organisms/100 ml	: Absent	IS:15185:2016	Absent
2	E. coli/100 ml.	: Absent	IS:15185:2016	Absent

Remarks: THE SAMPLE CONFORMS TO THE IS: 10500-2012 WITH RESPECT TO ABOVE TEST ONLY.
NOTE- FIGURE IN BRACKET INDICATE MINIMUM LIMIT OF QUANTIFICATION,(2)BLQ-BELOW LIMIT OF QUANTIFICATION.

Note 1.No deviation from the Standard Test Method / Specification is done unless specified or requested by the client 2. While giving the conformity statement laboratory does not consider Uncertainty Measurement into account 3. General terms and conditions are given on the back side of the report
URL-TC647123000008026F For report verification email to report_verify@delhitesthouse.com


Dr. (Mrs.) RAVIJA PRAKASH
Principal
Sachdeva Public School
Sector-13, Rohini, Delhi


SANJAY SACHDEVA
Manager
Sachdeva Public School
Sector-13, Rohini, Delhi


M.C. GOYAL
Authorised Signatory - Director

Page 01

ISO - 9001 : 2015 CERTIFIED LABORATORY

Other Lab : Plot No. 50 & 65, Phase - IV, Sector-57, HSIDC Industrial Estate, Behind Hasija Hospital, Kundli, Sonapat-131028 (Haryana)
: F - 402, Transoort Naagar, Kanour Road, Lucknow - 226012 (U.P.)

MUNICIPAL CORPORATION OF DELHI
(Office of Dy. Health Officer: Rohini Zone)
Public Health Department
Sector 5 Rohini Delhi -110085
Email: dhoroheinizone15@gmail.com Tel: 011-27052106

No.-DHO/RZ/2024/ 100

Date : 13/05/2024

SCHOOL HEALTH CERTIFICATE


It is certified that an inspection team headed Asst.Public health Inspector from Public Health department Rohini Zone inspected the **SACHDEVA PUBLIC SCHOOL** at **SEC-13, ROHINI New Delhi-110085** and found that the **SACHDEVA PUBLIC SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from date of issue.

Principal
SACHDEVA PUBLIC SCHOOL
SEC-13, ROHINI New Delhi-110085


Dr. (Mrs.) RAVIJA PRAKASH
Principal
Sachdeva Public School
Sector-13, Rohini, Delhi


Dy. Health Office
Rohini Zone
Deputy Health Officer
Municipal Corporation of Delhi
Rohini Zone


SANJAY SACHDEVA
Manager
Sachdeva Public School
Sector-13, Rohini, Delhi